

BASEC

BRITISH APPROVALS SERVICE FOR CABLES

Product Certification Schedule

Schedule No: 152/001/033
Licensee: VENTCROFT LIMITED, FARADAY ROAD, ASTMOOR INDUSTRIAL ESTATE, RUNCORN, CHESHIRE, WA7 1PE
Factory: VENTCROFT LIMITED, FARADAY ROAD, ASTMOOR INDUSTRIAL ESTATE, RUNCORN, CHESHIRE, WA7 1PE
Specification: BS 7629-1:2008 - Electric cables - Specification for 300/500 V fire resistant screened cables having low emission of smoke and corrosive gases when affected by fire - Part 1: Multicore and multipair cables
Type of Cable: Multicore cables
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: 1.0sqmm to 4sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. Sheath - LTS3. Insulation - EI2.
Origin Thread: Not applicable
Origin Mark: NOBURN PLATINUM or NOBURN PLUS

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 07/12/2016

Signed for and on behalf of the British Approvals Service for Cables

Date 21/01/2014

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004