



EC Declaration of Conformity

Product

NoBurn Platinum Range of Fire Performance Cables

Conformity:	Conforms to European Union (EU) Low Voltage Directive (LVD) 2006/95/EC
-------------	--

The Technical Construction File required by this directive is maintained at the head office of Ventcroft Ltd. Goddard Road, Astmoor Industrial Estate, Runcorn, Cheshire. WA7 1NQ. UK

Full compliance and third party approvals with the standards listed below prove the conformity of the designated product with the provisions of the above mentioned EC Directive.

Standards:	BS 7629-1:2008 BS EN 50200:2006 (PH120 classification) BS EN 50200:2006 + Annex E (30 minutes)
------------	--

This declaration is submitted by:

Ian Rotheram
Technical Director

On behalf of: Ventcroft Ltd. Goddard Road, Astmoor Industrial Estate
Runcorn, Cheshire. WA7 1NQ. UK

Ventcroft Limited
Goddard Road
Astmoor Industrial Estate
Runcorn, Cheshire
WA7 1NQ
England

Telephone: 01928 581098
Fax: 01928 581099
E-Mail: info@ventcroft.co.uk
Web: www.ventcroft.co.uk



Fire Performance Cable



Fire Control Panels



Intruder Cable



External Sounders



Disabled Person Alarm



Assessed to ISO 9001
LPCB ref no.682

Q:\Records\QMS19 - R&D Records\Projects\15 - Fire cable (Standard)\8.Project Review\Verification of Product\EC Declaration of Conformity - NoBurn Platinum.docx

Manufacturing Global Life Safety



CERTIFICATE NO:
CS1-196